

# Seminário de Transmissão de Energia em Linhas de Meia Onda

Campinas, SP - Brasil

**FEEC - UNICAMP**

26 e 27 de Novembro

$\lambda/2$  TMO  
2013



## Uso de FACTS para atendimento de pequenas cargas e controle de potência em Linhas de Meia Onda

Mauricio Aredes



# UFRJ

UNIVERSIDADE FEDERAL DO RIO DE JANEIRO



Power Electronics and Medium Voltage Laboratory  
COPPE / UFRJ



Linhas de pouco mais que meio comprimento de onda ( $\lambda/2^+$ ) não se configuram como um sistema de transmissão estritamente ponto-a-ponto

FACTS para controle de fluxo de potência em LT Meia-Onda


Derivação de energia em LT Meia-Onda

LT Meia-Onda ( $\lambda/2^+$ )

Configuração multiterminal sem descaracterizar LT Meia-Onda



# Lines longer than half the wavelength – voltage and current profile –





$$P_C = \frac{U_o^2}{Z_c}$$



# Lines longer than half the wavelength

– transmitted active power,  $P_{SR}$  –




$$P_{SR} = \frac{V_0^2}{\sqrt{\frac{L}{C}} \sin(\Theta)} \sin(\delta)$$

$\sin(\Theta) < 0$



# Series and shunt compensation of lines



$$Z'_c = \sqrt{\frac{\xi}{\eta}} \cdot Z_c = \sqrt{\frac{\xi}{\eta}} \cdot \sqrt{\frac{L}{C}}$$

$$\Theta' = \sqrt{\xi\eta} \cdot \Theta = \sqrt{\xi\eta} \cdot \omega\sqrt{LC} \cdot \ell$$


capacitive series  
compensation:  $\xi < 1.0$

inductive shunt  
compensation:  $\eta < 1.0$


$$P_{SR} = \frac{U_o^2}{\sqrt{\frac{\xi}{\eta}} \cdot Z_c \sin(\sqrt{\xi\eta} \cdot \Theta)} \sin(\delta)$$



Analytical model of the  $\lambda/2^+$  line and the **shunt** FACTS positioned at  $\Theta_{tap}$



Analytical model of the  $\lambda/2^+$  line and the **series** FACTS positioned at  $\Theta_{tap}$






# Power flow control as a function of the FACTS position


## series FACTS

$$|U_{tap}| = 0.2 \text{ p.u.}$$



## shunt FACTS

$$|I_{tap}| = 0.2 \text{ p.u.}$$



- a** section of the  $\lambda/2^+$  line: active power can be derived from/to the  $\lambda/2^+$  line with negligible influence in the main power flow (Tapping functionality)
- b** section of the  $\lambda/2^+$  line: reactive power compensation varies significantly the main power flow (Power Flow Controller)




# Voltage profile along the $\lambda/2^+$ line as a function of the X/R ratio of the FACTS

- The FACTS is connected in the central section of the line


## series FACTS

$$|U_{tap}| = 0.2 \text{ p.u.}$$



## shunt FACTS

$$|I_{tap}| = 0.2 \text{ p.u.}$$








# Summing up...

- The voltage profile and the transmitted power of a  $\lambda/2^+$  line are very sensitive to a **shunt** FACTS located at the central section of the line.
- A **series** FACTS is very effective in controlling the main power flow through the  $\lambda/2^+$  line when it is connected at the terminal sections of the line.
- More than one **shunt** FACTS can be connected at a terminal section of the  $\lambda/2^+$  line to configure a multiterminal arrangement (fractional active power derivation).




# FACTS for Tapping and Power Flow Control in Half-Wavelength Transmission Lines






# Shunt FACTS for Tapping and Power Flow Control in Half-Wavelength Transmission Lines






# Controller of the Converter #1 of the Shunt FACTS






# Controller of the Converter #1 of the Shunt FACTS






# Controller of the Converter #2 of the Shunt FACTS






# Controller of the Converter #2 of the Shunt FACTS






# Series FACTS for Tapping and Power Flow Control in Half-Wavelength Transmission Lines








# Controller of the Converter #1 of the Series FACTS






# Controller of the Converter #1 of the Series FACTS






# Controller of the Converter #2 of the Series FACTS






# Controller of the Converter #2 of the Series FACTS






# A shunt FACTS in the central section of the Half-Wavelength Transmission Line





# Simulation Results


## Sequence of Events





# Shunt FACTS:


## Active power through the $\lambda/2^+$ lines #1 and #2





# Shunt FACTS:


## Active power exchange between the $\lambda/2^+$ line and the local ac system








# Active and reactive power of converter #1 of the Shunt FACTS






## Shunt FACTS: dc-bus capacitor voltages of the NPC-Converter





# A series FACTS connected 450 km far from the sending-end terminal






# Series FACTS simulation case

## Sequence of events

Time	Event
$t_1 = 1.0\text{s}$	HVAC series tap is connected to the line
$t_2 = 1.1\text{s}$	The tap is connected to the local system with $P_{\text{tap}} = 0$
$t_3 = 3.0\text{s}$	Step change to $P_{\text{tap}} = +500$ (the series tap drains 500 MW from the line)
$t_4 = 5.0\text{s}$	The $P_{\text{ORDER}}$ order changes to 8.0 GW (1.0 pu)
$t_5 = 6.0\text{s}$	Step change to $P_{\text{tap}} = -500$ (the series tap injects 500 MW into the line)
$t_6 = 8.0\text{s}$	The $P_{\text{ORDER}}$ changes to 6.0 GW
$T_7 = 10.0\text{s}$	Step change to $P_{\text{tap}} = +330$ (the series tap drains 330 MW from the line)




# Series FACTS: Active power in the $\lambda/2^+$ line #1






# Series FACTS:

## Active power exchange between the $\lambda/2^+$ line and the local ac system





# Series FACTS performing only HVAC tapping (no power flow control in the $\lambda/2^+$ line)





# Summing up

- **Shunt FACTS** is an attractive solution for main power flow control and fractional power derivation in  $\lambda/2^+$  lines, if connected in the central section of the line;
- Several **shunt** FACTS can be used to configure multiterminal system;
- The **series** FACTS is an attractive solution for main power flow and fractional power derivation in  $\lambda/2^+$  lines, if connected in the terminal section of the line.





# REFERENCES

1. E. H. Watanabe, M. Aredes and C. Portela, "Electric Energy and Environment: Some Technological Challenges in Brazil," in *Energy and Environment – Technological Challenges for the Future*, Y. H. Mori and K. Ohnishi, Eds. Tokyo: Springer-Verlag, 2001, pp. 10-40, ISBN: 4-431-70293-8.
2. Gilson Ferreira dos Santos Júnior, "Avaliação de uma Linha de Transmissão de Meio Comprimento de Onda Controlada por um Dispositivo FACTS," M.Sc. Dissertation, *UFRJ/COPPE - Department of Electrical Engineering*, Rio de Janeiro, February 2003.
3. C. Portela and M. Aredes, "Very Long Distance Transmission," in *Proc. International Scientific and Technical Conference on "AC Power Delivery at Long and Very Long Distances,"* vol. 1, pp. 385-394, Novosibirsk, Russia, 15-19 September 2003.
4. M. Aredes, E. L. van Emmerik, R. F. S. Dias and C. Portela, "FACTS Applied to Very Long Distance Transmission Lines," in *Proc. International Scientific and Technical Conference on "AC Power Delivery at Long and Very Long Distances,"* vol. 1, pp. 395-403, Novosibirsk, Russia, 15-19 September 2003.
5. M. Aredes, E. M. Sasso, E. L. van Emmerik, C. Portela, "The GTO-Controlled Series Capacitor Applied to Half-Wave Length Transmission-Lines," in *Proc. IPST'2003 – Int. Conf. on Power System Transients*, pp. 1-6, New Orleans, USA, 2003.



## REFERENCES

6. M. Aredes, C. Portela, E. L. van Emmerik, R. F. da Silva Dias, "Static series compensators applied to very long distance transmission lines," *Electrical Engineering Research Journal – Archiv für Elektrotechnik*, ISSN 0948-7921, vol. 86, no. 2, pp. 69-76, January 2004.
7. Robson Francisco da Silva Dias, "Derivação ou Injeção de Energia em uma Linha de Transmissão de Pouco mais de Meio Comprimento de Onda por meio de Dispositivos FACTS," D.Sc. Thesis, *UFRJ/COPPE - Department of Electrical Engineering*, Rio de Janeiro, March 2008.
8. R. F. S. Dias, A. C. S. Lima, C. Portela, M. Aredes, "Non-Conventional Transmission Line with FACTS in Electromagnetic Transient Programs," in *Proc. IPST 2009 – Int. Conf. on Power Systems Transients*, pp. 1-7, Kyoto, 2009.
9. M. Aredes, R. F. S. Dias, A. F. C. Aquino, C. Portela, E. H. Watanabe, "Power Electronics Applications in Bulk Power Transmission over Long Distances," in *Proc. ISIE 2010 - IEEE Int. Symposium on Industrial Electronics*, pp. 3757 - 3765, Bari, Italy, 4-7 July 2010.
10. M. Aredes, R. F. S. Dias, "A Shunt FACTS Device for Tapping Power Flow Control in Half-Wavelength Transmission Lines," in *Proc. of the APPEEC – IEEE 2011 - Asia – Pacific Power and Energy Engineering Conference*, Wuhan, China, 25-28 March 2011, pp. 1-6.



## REFERENCES

11. R. Dias, A. Lima, C. Portela, M. Aredes, "Extra Long-Distance Bulk Power Transmission," *IEEE Trans. Power Delivery*, vol. 26, no. 3, pp. 1440-1448, July 2011.
12. M. Aredes, R. F. S. Dias, A. F. C. Aquino, C. Portela, E. H. Watanabe, "Going the Distance – Power-Electronics-Based Solutions for Long-Range Bulk Power Transmission," *IEEE Industrial Electronics Magazine*, vol.5, no. 1, pp. 36-48, Mar. 2011.
13. M. Aredes, R. Dias , "FACTS for Tapping and Power Flow Control in Half-Wavelength Transmission Lines," *IEEE Transactions on Industrial Electronics*, vol.59, no.10, pp.3669-3679, Oct. 2012.
14. 135. M. Aredes, R. Dias, "Comparisons between a Series and a Shunt FACTS for Tapping and Power Flow Control in Half-Wavelength Transmission Lines," in *Proc. of the EPE-PEMC 2012 ECE Europe – 15<sup>th</sup> International Power Electronics and Motion Control Conference*, Novi Sad, Serbia, 4-7 September 2012, pp. 1-7.
15. H. Akagi, E. Watanabe, M. Aredes, "Instantaneous Power Theory and Applications to Power Conditioning", Wiley-IEEE Press, 2007.

# *Obrigado!*

謝謝

# *СПАСИБО*



# UFRJ

Maurício Aredes  
[www.lem.t.ufrj.br](http://www.lem.t.ufrj.br)